

Tim Brown

From: Bekta, Eugene D - DNR <Eugene.Bekta@wisconsin.gov>
Sent: Wednesday, June 3, 2020 3:31 PM
To: Tim Brown
Subject: RE: Construction Site Storm Water Discharge Permit Coverage

Thank you Tim.

This work can be included under the current DNR storm water permit. However, as City of Milton is a permitted MS4, DNR defers to the city for any additional storm water requirements.

Please contact me with questions or concerns.

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

E. Dan Bekta, P.E.

Cell: (608)333-6579

Eugene.Bekta@Wisconsin.gov



From: Tim Brown
Sent: Wednesday, June 03, 2020 3:17 PM
To: Bekta, Eugene D - DNR
Subject: RE: Construction Site Storm Water Discharge Permit Coverage

Eugene,

Attached are two rough sketches, the permitted file is the one that you have seen and approved. The new file is the potential redesign without the garages. Would these need to be fully re-permitted?

Sincerely,
Tim

Tim Brown, P.E.
p 414.249.6108. Ext. 105

Eriksson Engineering Associates, Ltd.
Illinois Wisconsin Indiana | www.eea-ltd.com
Ready for a new challenge? [Join the EEA team](#) →

From: Bekta, Eugene D - DNR <Eugene.Bekta@wisconsin.gov>
Sent: Wednesday, June 3, 2020 3:04 PM
To: Tim Brown <tbrown@eea-ltd.com>
Subject: RE: Construction Site Storm Water Discharge Permit Coverage

Hello Tim,

Thank you for the update, if you can send a sketch of the changes, that would be good.

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

E. Dan Bekta, P.E.

Cell: (608)333-6579

Eugene.Bekta@Wisconsin.gov



From: Tim Brown <tbrown@eea-ltd.com>

Sent: Wednesday, June 03, 2020 3:00 PM

To: Bekta, Eugene D - DNR <Eugene.Bekta@wisconsin.gov>

Subject: RE: Construction Site Storm Water Discharge Permit Coverage

Eugene,

We received a request from the owner of the project to remove the garages in the parking lot. I want to reach out to you to see if you would need to rereview the project or if this could be handled as a field change. If anything, this change will result in more pervious area (removing garage roofs and installing landscaped islands) with less underground pipe. Please feel free to call me to discuss.

Thank you,
Tim

Tim Brown, P.E.

p 414.249.6108. Ext. 105

Eriksson Engineering Associates, Ltd.

Illinois Wisconsin Indiana | www.eea-ltd.com

Ready for a new challenge? [Join the EEA team](#) →

From: Bekta, Eugene D - DNR <Eugene.Bekta@wisconsin.gov>

Sent: Wednesday, October 23, 2019 3:37 PM

To: Tim Brown <tbrown@eea-ltd.com>

Subject: Construction Site Storm Water Discharge Permit Coverage

Good afternoon Tim,

DNR has issued construction site **Storm Water Permit Coverage** for **Red Hawk Apartments, City of Milton, WDNR FIN 68831**. The coverage is effective today, **October 23, 2019**.

A hard copy of the letter of coverage and certificate will be mailed to **Jeremy Yost** of **Yost Management**. An electronic copy is attached for your use.

Thank you for your submittal and please contact me with questions or concerns.

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

E. Dan Bekta, P.E.

Water Resources Engineer- Bureau of Watershed Management/Division of External Services

Wisconsin Department of Natural Resources


3911 Fish Hatchery Road

Fitchburg, Wisconsin 53711

Cell: 608-333-6579

Eugene.Bekta@Wisconsin.gov





1-STORY SINGLE FAMILY HOME

SINGLE FAMILY HOME

DAILY

BUILDING B
3-STORY APARTMENT BUILDING
(36 UNITS)

PROPOSED UNCOVERED PARKING
(186 SPACES INCL. 7 ACCESS.)

BUILDING A
3-STORY APARTMENT BUILDING
(36 UNITS)

BUILDING C
3-STORY APARTMENT BUILDING
(36 UNITS)

3-STORY APARTMENT BUILDING

2-STORY APARTMENT BUILDING

1-STORY PARKING GARAGE

1-STORY PARKING GARAGE

9'-0"

65'-7"

28'-3"

82'-16"

S87°46'53"E 245.45'

S87°24'22"E 210.62'

S87°39'03"E 177.59'

- 213.11' -
S87°31'05"E 177.57'

N87°46'53"W 5269.31'
20' ELECTRIC EASEMENT
PER DOC. NO. 2063134
20' WATERMAN EASEMENT
PER DOC. NO. 2063371

10.00'
10' UTILITY EASEMENT
PER DOC. NO. 2063743

785.92'

N02°17'45"E 285.24'

N02°17'45"E 64.64'

N49°47'36"E 98.45'

N38°57'05"E 248.65'

S24°45'59"W 615.42'

